

Water Testing Laboratory,
Motipur, Mandi (H.P.)



TEST REPORT

Sample No: 3330/2 Date: 07/02/2026
Environmental Condition: Temperature 23.2°C ± 2 Relative Humidity 55%.

Test Report No.: MDP/806
Name & Address Of Customer: Assistant Engineer Civil IIT Kamand Mandi (H.P.)
Sampling Method: IS/APHA
Sample Description: Drinking Water
Sample Quantity: 2lt.
Collected on: 05/02/2026
Test Start Date: 05/02/2026
Test End Date: 07/02/2026
Condition of Sample When Received: Good
Name of Source/Scheme: Scheme Source
Name of Panchayat: Kamand
Name of Habitation: IIT Mandi
Name of Village: Kamand
Type of Source: Treated Water
Sample Submitted By: Sh. Hemraj

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
Physical Parameter						
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	7.25		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	5	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	Agreeable	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	Agreeable	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephelometric method	1.6	N.T.U.	1 NTU Max	5 NTU Max
Chemical Parameter						
6	Total hardness as CaCO ₃	IS-3025 (PART-21)-2009, Reaff. 2019, 2023 EDTA Titration Method	88	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as CaCO ₃	IS-3025 (PART-23) 2023 Indicator method	96	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff. 2019 Argentometric method	15.49	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23 rd Edition 2540-(Part-C) Total Dissolved solids (Dried at 180 degree Celsius)	115	Mg/l	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24 th Edition 3500-Ca Method B (EDTA Titrimetric method)	20.84	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	7.29	Mg/l	30mg/l Max	100mg/l Max

- Note:
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
 - The results refer only to tested samples and parameters tested.
 - The samples will be stored for a period of 7 days from the date of issue of report.

-----END OF REPORT-----

Reviewed By :- *Aparajita*

Aparajita
Authorized Signatory
Water Testing Laboratory
Motipur, Mandi (H.P.)
Water Testing Laboratory
Motipur, Mandi (H.P.)

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MDP/806

GR No. 1606868

Name and Address of Sender Assistant Engineer Civil IIT Kamand Mandi (H.P.)
 Division..... Sub-Division.....
 Section..... Name of District: Mandi
 Name of Block: Sadar Name of Panchyat: Kamand
 Name of Village: Ramand Name of Habitation(s): IIT Mandi
 Name of Scheme and Location of Source: Tap at Dining Hall D₂

Type of Source : Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.
 Date and time of collection 05/02/2026 Date & Time of Receipt at Laboratory 05/02/2026 11:30 am
 Date & time of Commencing 05/02/2026 to 07/02/2026
 Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

limits :Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETER


S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits[in the absence of alternate source]	Result
1.	Temperature	°C	-	-	22.2°C


(B) MICROBIOLOGICAL PARAMETER

2.	Total Coliforms	Number/100ml	Nil	Nil	Nil
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Nil	Nil	Nil

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks On the basis of the sample given in the laboratory this sample is found fit for drinking consumption.


Microbiologist
 Jal Shakti Vibhag
 Water Testing Lab. Mandi (H.P.)


Junior Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)


Assistant Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)

**Water Testing Laboratory,
Motipur, Mandi (H.P.)**



TEST REPORT

Sample No: 3330/4	Date: 07/02/2026
Environmental Condition: Temperature 23.2 ± 2°C	Relative Humidity 55%

Test Report No.: **MDP/808**
 Name & Address Of Customer: **Assistant Engineer Civil IIT Kamand Mandi (H.P.)**
 Sampling Method: **IS/APHA**
 Sample Description: **Drinking Water**
 Sample Quantity: **2lt.**
 Collected on: **05/02/2026**
 Test Start Date: **05/02/2026**
 Test End Date: **07/02/2026**


Condition of Sample When Received: **Good**
 Name of Source/Scheme: **Scheme Source**
 Name of Panchayat: **Kamand**
 Name of Habitation: **IIT Mandi**
 Name of Village: **Kamand**
 Type of Source: **Treated Water**
 Sample Submitted By: **Sh. Hemraj**

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
Physical Parameter						
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	7.39 at 23.2c		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	5	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	Agreeable	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	Agreeable	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephelometric method	1.8	N.T.U.	1 NTU Max	5 NTU Max
Chemical Parameter						
6	Total hardness as CaCO ₃	IS-3025 (PART-21)-2009,Reaff.2019,2023EDTA Titration Method	92	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as CaCO ₃	IS-3025 (PART-23) 2023 Indicator method	104	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff.2019 Argentometric method	17.99	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23 rd Edition 2540-(Part-C)Total Dissolved solids (Dried at 180 degree Celsius)	130	Mg/l	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24 th Edition.3500-Ca Method B (EDTA Titremetric method)	21.64	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	5.34	Mg/l	30mg/l Max	100mg/l Max

- Note:**
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
 - The results refer only to tested samples and parameters tested.
 - The samples will be stored for a period of 7 days from the date of issue of report.

-----END OF REPORT-----

Reviewed By :- **Apurajita**


Authorized Signatory
 Water Testing Laboratory
 Motipur, Mandi (H.P.)
 Water Testing Laboratory
 Motipur, Mandi (H.P.)

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MDP/808

GR No. 160.6868

Name and Address of Sender... Assistant Engineer (Civil) I.T. Kamand Mandi (H.P.)
 Division..... Sub-Division.....
 Section..... Name of District: Mandi
 Name of Block... Sadar..... Name of Panchyat... Kamand
 Name of Village... Kamand..... Name of Habitation(s)... I.T. Mandi
 Name of Scheme and Location of Source... Tapat Girls Hostel B8

Type of Source : Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.
 Date and time of collection... 05/02/2026... Date & Time of Receipt at Laboratory... 05/02/2026 11:30 am
 Date & time of Commencing... 05/02/2026 to 07/02/2026
 Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

limits :Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETER


S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits [in the absence of alternate source]	Result
1.	Temperature	°C	-	-	<u>23.2 °C</u>


(B) MICROBIOLOGICAL PARAMETER


2.	Total Coliforms	Number/100ml	Nil	Nil	<u>Nil</u>
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Nil	Nil	<u>Nil</u>

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks... On the basis of the sample given in the laboratory this sample is found fit for drinking consumption.


Microbiologist
Jal Shakti Vibhag
Water Testing Lab. Mandi (H.P.)


Junior Engineer
Jal Shakti Vibhag
Sub-Division-Mandi(H.P.)


Assistant Engineer
Jal Shakti Vibhag
Sub-Division-Mandi(H.P.)

**Water Testing Laboratory,
Motipur, Mandi (H.P.)**



TEST REPORT

Sample No: 3330/1	Date: 07/02/2026
Environmental Condition: Temperature 23.2°C ± 2	Relative Humidity 55.1%

Test Report No.: **MDP/805**
 Name & Address Of Customer: **Assistant Engineer Civil, IIT Kamand Mandi (H.P.)**
 Sampling Method: **IS/APHA**
 Sample Description: **Drinking Water**
 Sample Quantity: **2lt.**
 Collected on: **05/02/2026**
 Test Start Date: **05/02/2026**
 Test End Date: **07/02/2026**


Condition of Sample When Received: **Good**
 Name of Source/Scheme: **Scheme Source**
 Name of Panchayat: **Kamand**
 Name of Habitation: **IIT Mandi**
 Name of Village: **Kamand**
 Type of Source: **Treated Water**
 Sample Submitted By: **Sh. Hemraj**

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
Physical Parameter						
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	7.39 <i>at 23.2°C</i>		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	5	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	Agreeable	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	Agreeable	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephelometric method	1.5	N.T.U.	1 NTU Max	5 NTU Max
Chemical Parameter						
6	Total hardness as CaCO ₃	IS-3025 (PART-21)-2009, Reaff.2019,2023 EDTA Titration Method	98	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as CaCO ₃	IS-3025 (PART-23) 2023 Indicator method	102	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff.2019 Argentometric method	15.99	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23 rd Edition 2540-(Part-C) Total Dissolved solids (Dried at 180 degree Celsius)	140	Mg/i	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24 th Edition 3500-Ca Method B (EDTA Titremetric method)	24.85	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	6.80	Mg/l	30mg/l Max	100mg/l Max

- Note:**
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
 - The results refer only to tested samples and parameters tested.
 - The samples will be stored for a period of 7 days from the date of issue of report.

-----END OF REPORT-----

Reviewed By :- **Aparajita**


 Authorized Signatory
 Water Testing Laboratory
 Motipur, Mandi (H.P.)
 Water Testing Laboratory
 Motipur, Mandi (H.P.)

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MDP/805

GR No. 1606868

Name and Address of Sender: *Assistant Engineer Civil IIT Kamand Mandi (H.P.)*
 Division..... Sub-Division.....
 Section..... Name of District: *Mandi*
 Name of Block: *Sadar* Name of Panchyat: *Kamand*
 Name of Village: *Kamand* Name of Habitation(s): *IIT Mandi*
 Name of Scheme and Location of Source: *Tap at Faculty Housing C I*

Type of Source : Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.
 Date and time of collection: *05/02/2026* Date & Time of Receipt at Laboratory: *05/02/2026 11:30 am*
 Date & time of Commencing: *05/02/2026* to *07/02/2026*
 Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

limits :Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETER

S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits [in the absence of alternate source]	Result
1.	Temperature	°C	-	-	<i>23.2°C</i>

(B) MICROBIOLOGICAL PARAMETER

2.	Total Coliforms	Number/100ml	Nil	Nil	<i>Nil</i>
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Nil	Nil	<i>Nil</i>

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks *On the basis of the sample given in the laboratory, this sample is found fit for drinking consumption.*

[Signature]
Microbiologist
 Jal Shakti Vibhag
 Water Testing Lab. Mandi (H.P.)

[Signature]
Junior Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)

[Signature]
Assistant Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)

**Water Testing Laboratory,
Motipur, Mandi (H.P.)**



TEST REPORT

Sample No: <u>3330/3</u>	Date: <u>07/02/2026</u>
Environmental Condition: Temperature <u>23.2 ± 2 °C</u>	Relative Humidity <u>55%</u>

Test Report No.: MDP/807
 Name & Address Of Customer: Assistant Engineer Civil, 11T Kamand Mandi (H.P.)
 Sampling Method: IS/APHA
 Sample Description: Drinking Water
 Sample Quantity: 2lt.
 Collected on: 05/02/2026
 Test Start Date: 05/02/2026
 Test End Date: 05/02/2026

Condition of Sample When Received: Good
 Name of Source/Scheme: Scheme Source
 Name of Panchayat: Kamand
 Name of Habitation: 11T Mandi
 Name of Village: Kamand
 Type of Source: Treated Water
 Sample Submitted By: Sh. Hemraj

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
Physical Parameter						
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	<u>7.41</u> <u>23.2 °C</u>		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	<u>5</u>	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	<u>Agreeable</u>	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	<u>Agreeable</u>	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephelometric method	<u>2.7</u>	N.T.U.	1 NTU Max	5 NTU Max
Chemical Parameter						
6	Total hardness as CaCO ₃	IS-3025 (PART-21)-2009,Reaff.2019,2023EDTA Titration Method	<u>102</u>	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as CaCO ₃	IS-3025 (PART-23) 2023 Indicator method	<u>98</u>	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff.2019 Argentometric method	<u>16.49</u>	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23 rd Edition 2540-(Part-C)Total Dissolved solids (Dried at 180 degree Celsius)	<u>140</u>	Mg/l	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24 th Edition 3500-Ca Method B (EDTA Titrimetric method)	<u>23.24</u>	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	<u>6.80</u>	Mg/l	30mg/l Max	100mg/l Max

- Note:**
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
 - The results refer only to tested samples and parameters tested.
 - The samples will be stored for a period of 7 days from the date of issue of report.

-----END OF REPORT-----

Reviewed By :- Aparajita

Aparajita
 Authorized Signatory
 Water Testing Laboratory
 Motipur, Mandi (H.P.)
 Water Testing Laboratory
 Motipur, Mandi (H.P.)

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MOP/807

GR No. 1606868

Name and Address of Sender: *Assistant Engineer Civil IT Kamand Mandi (H.P.)*
 Division..... Sub-Division.....
 Section..... Name of District: *Mandi*
 Name of Block: *Sadar* Name of Panchyat: *Kamand*
 Name of Village: *Kamand* Name of Habitation(s): *IT Mandi*
 Name of Scheme and Location of Source: *Tap at Boys Hostel B9*

Type of Source : Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.

Date and time of collection: *05/02/2026* Date & Time of Receipt at Laboratory: *05/02/2026 11:30am*

Date & time of Commencing: *05/02/2026 to 07/02/2026*

Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

limits :Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETER

S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits[in the absence of alternate source]	Result
1.	Temperature	°C	-	-	<i>23.2°C</i>

(B) MICROBIOLOGICAL PARAMETER

2.	Total Coliforms	Number/100ml	Nil	Nil	<i>Nil</i>
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Nil	Nil	<i>Nil</i>

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks *On the basis of the sample given in the laboratory this sample is found fit for drinking consumption.*

[Signature]
Microbiologist
 Jal Shakti Vibhag
 Water Testing Lab. Mandi (H.P.)

[Signature]
Junior Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)

[Signature]
Assistant Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)

**Water Testing Laboratory,
Motipur, Mandi (H.P.)**



TEST REPORT

Sample No: 3330/5	Date: 07/02/2026
Environmental Condition: Temperature 23.2 ± 2°C	Relative Humidity 55%
Test Report No.: MDP/809	
Name & Address Of Customer: Assistant Engineer Civil IIT Kamand Mandi (H.P.)	Condition of Sample When Received: Good
Sampling Method: IS/APH A	Name of Source/Scheme: Scheme Source
Sample Description: Drinking Water	Name of Panchayat: Kamand
Sample Quantity: 2lt.	Name of Habitation: IIT Mandi
Collected on: 05/02/2026	Name of Village: Kamand
Test Start Date: 05/02/2026	Type of Source: Treated Water
Test End Date: 07/02/2026	Sample Submitted By: Sh. Hemraj

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
Physical Parameter						
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	7.27 at 23.2°C		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	5	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	Agreeable	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	Agreeable	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephelometric method	1.6	N.T.U.	1 NTU Max	5 NTU Max
Chemical Parameter						
6	Total hardness as CaCO ₃	IS-3025 (PART-21)-2009, Reaff.2019, 2023 EDTA Titration Method	98	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as CaCO ₃	IS-3025 (PART-23) 2023 Indicator method	112	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff.2019 Argentometric method	16.99	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23 rd Edition 2540-(Part-C) Total Dissolved solids (Dried at 180 degree Celsius)	150	Mg/l	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24 th Edition 3500-Ca Method B (EDTA Titrimetric method)	24.85	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	6.80	Mg/l	30mg/l Max	100mg/l Max

- Note:**
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
 - The results refer only to tested samples and parameters tested.
 - The samples will be stored for a period of 7 days from the date of issue of report.

-----END OF REPORT-----

Reviewed By :-

Aparajita

Aparajita
 Authorized Signatory
 Water Testing Laboratory
 Motipur, Mandi (H.P.)
 Authorized Signatory
 Water Testing Laboratory
 Motipur, Mandi (H.P.)

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MDP/809

GR No. 1606868

Name and Address of Sender: Assistant Engineer (Civil) IIT Kamand Mandi (H.P.)
 Division..... Sub-Division.....
 Section..... Name of District: Mandi
 Name of Block: Sadar Name of Panchyat: Kamand
 Name of Village: Kamand Name of Habitation(s): IIT Mandi
 Name of Scheme and Location of Source: Tap at Main Tank South and North

Type of Source : Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.
 Date and time of collection: 05/02/2026 Date & Time of Receipt at Laboratory: 05/02/2026 11:30 AM
 Date & time of Commencing: 05/02/2026 to 07/02/2026
 Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

limits : Based upon BIS : 10500-2012

(A) PHYSICAL PARAMETER


S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits[in the absence of alternate source]	Result
1.	Temperature	°C	-	-	23.2°C


(B) MICROBIOLOGICAL PARAMETER

2.	Total Coliforms	Number/100ml	Nil	Nil	Nil
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Nil	Nil	Nil

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks: On the basis of the sample given in the laboratory, this sample is found fit for drinking consumption.


Microbiologist
 Jal Shakti Vibhag
 Water Testing Lab. Mandi (H.P.)


Junior Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)


Assistant Engineer
 Jal Shakti Vibhag
 Sub-Division-Mandi(H.P.)